

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193175
Address: 1100 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Khanh Nguyen	Partial	Friday, September 25, 2020

Partial Correction:

1

TWO PIERS AT OUTER CORNERS ARE OK TO POUR; HOWEVER, CHECK IF THE PLAN CALLS FOR MIDDLE PIER TO SUPPORT FLOOR LOAD

Comments: