

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

September 25, 2020

SDC ENGINEERING 5907 RAYTOWN TFWY RAYTOWN, MO 64133

Permit No: PRCOM20202233
Project Title: GLOSS NAIL

Project Address: 470 NW CHIPMAN RD, LEES SUMMIT, MO 64086

Parcel Number: 52900036200000000

Location / Legal SUMMIT ORCHARD LOTS 4A-4E --- LOT 4B

Description:

Type of Work: NEW TENANT FINISH

Occupancy Group: BUSINESS

Description: TENANT FINISH FOR NAIL SALON

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. (Informational Purposes)

Any modifications to the fire alarm system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofls.net

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Informational Purposes)

Any modifications to the fire sprinkler system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofls.net



DEVELOPMENT SERVICES

3. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

4. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort. (Verified At Inspection)

Building Plan Review Reviewed By: Joe Frogge Rejected

2. 2018 IPC 403.1 Minimum number of fixtures. Plumbing fixtures shall be provided in the minimum number shown in Table 403.1, based on the actual use of the building or space. Uses not shown in Table 403.1 shall be considered individually by the code official. The number of occupants shall be determined by the International Building Code.

Action required: Provide additional water closets for compliance.

9/24/20:

- Additional water closets to be added to both restrooms.
- Partition required at urinal
- If locks are proved on doors it will defeat the purpose of multiple fixtures.

Licensed Contractors Reviewed By: Joe Frogge Approved

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.