

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 640812001 NW SHAMROCK AVE, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement Surface</b>	Ronald Paynter	Partial	Saturday, September 26, 2020

Informational:

1 Misc

Thorne & Sons laid 590 tons of APWA Type 01-01 Recycled asphalt for the base. Terracon was on site doing compaction testing. All test results were in the 97 to 98 percent compaction range. RP 9-26-20

**Comments:**