

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193580  
Address: 920 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Michael Harkins	Partial	Friday, September 25, 2020

Corrective Action Required:

1	Misc	- HOOD/DUCT INSTALLER NO SHOW -
Informational:		
2	Misc	- 10' SECTION ON GROUND WELDS APPROVED -

**Comments:**