## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20201877 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                    |                | Inspector:   | Outcome:  | Date:  |  |  |
|--|----------------|--|---|--|--|--|
| DE - Sanitary Sewer<br>Construction Inspection |                | John Jackson   | Partial   | Monday, September<br>28, 2020  |  |  |
| Informational:                                 |                |  |   |  |  |  |
| 1  | Misc           | · · · ·  | ontractor (Holthouse- Marty<br>nd installing newly approve  |  |  |  |
| Informat                                       | Informational: |  |   |  |  |  |
| 2  | Misc           | 9/2/20 Wednesday Contractor installed three service lines on 9/1/20 Tuesday<br>Lots 136,137, & 147.<br>9:00 AM Today Contractor has installed wyes and stub lines for Lots 138, & 146<br>so far. Contractor will pour trench checks for yesterday and today's stubs.<br>I reminded the Contractor (Holthouse - Marty) about rolling the wyes<br>between 30 & 45 degree as specified in the Design Construction Manual! |   |  |  |  |
| Informational:                                 |                |  |   |  |  |  |
| 3  | Misc           | 145 yesterday.   | or also completed wyes and<br>r has completed wye and la  |  |  |  |
| Informational:                                 |                |  |   |  |  |  |
| 4  | Misc           | were installed for Lot 142<br>wye one amatory was us<br>pipe as per specifications<br>is being installed (Seedoo   | nstalled lateral line for Lot<br>Maxadaptor was used tie in<br>ed. Contractor was able to t<br>. Two sleeve Maxadaptors a<br>cuments or additions pictur<br>back to Lot 120 and finishe | n when there were two<br>ie-in onside to existing<br>are used when one wye<br>e associated with this |  |  |

|                | that was stop due to weather and ground conditions. Contractor has called for flowable fill for trench checks on laterals   |  |  |  |
|----------------|---|--|--|--|
| Informational: |   |  |  |  |
| 5 Misc         | 9/9/20 9:00AM<br>On 9/8/20 Contractor (Holthouse) installed sanitary laterals with Maxadaptor<br>for Lots 117 and 118 and poured ditch checks. Today contractor is working on<br>working on Lot 119 and 135.  |  |  |  |
| Informational: |   |  |  |  |
| 6 Misc         | 9/15/20 9:00AM Tuesday<br>On 9/14/20 Monday contractor installed sanitary lateral for Lot 135 and<br>excavated existing MH C-6 to core for new sanitary 8" pipe. 9/15/20 Monday<br>coring was completed on MH C-6 and contractor began removal soil from<br>site. |  |  |  |
| Informational: |   |  |  |  |
| 7 Misc         | 9/15/20 2:30PM Tuesday<br>On 9/15/20 Contractor installed approximately 150' of 8" sanitary pipe on<br>Line 1.  |  |  |  |
| Informational: |   |  |  |  |
| 8 Misc         | 9/16/20 3:11PM Tuesday<br>On 9/16/20 Contractor installed MH 1-1 and 1-2 on Line 1. Contractor installed<br>approximately 180' of 8" SDR-26 PVC on Line 1. Laterals were installed on Lot<br>131 & 132.   |  |  |  |
| Informational: |   |  |  |  |
| 9 Misc         | 9/17/20 Thursday<br>Contractor installed lateral on Lot 130, 133, & 134 and ditch checks were<br>poured with flowable fill.   |  |  |  |
| Informational: |   |  |  |  |
| 10 Misc        | 9/18/20 Friday<br>Contractor finished pouring ditch checks on laterals & completed the install<br>of MH 1-1. Contractor backfill excavation for Line 1. Note: Lateral for Lot 128<br>was completed on 9/16/20 this is not reflected on my 9/16/20 report.         |  |  |  |
| Informational: |   |  |  |  |
| 11 Misc        | 9/21/20 Monday<br>Contractor (Holthouse Const.) installed 240' of 8" SDR - 26 8"x4" wye for Lot<br>148.   |  |  |  |
| Informational: |   |  |  |  |
| 12 Misc        | 9/22/20 Tuesday<br>Contractor Installed approximately 105' of 8" SDR -26 and laterals to Lot 116,<br>148 & 149.   |  |  |  |
| Informational: |   |  |  |  |
| 13 Misc        | 9/23/20 Wednesday<br>Contractor (Holthouse Construction) pour trench checks for laterals installed<br>on 9/22/20.<br>Approximately 200' of 8" SDR- 26 sewer pipe was installed.   |  |  |  |
| Informational: |   |  |  |  |
| 14 Misc        | 9/24/20 Thursday<br>Contractor installed laterals on Lots 115,114 &,113. The bottom half of MH 2-2<br>was set.  |  |  |  |
| Informational: |   |  |  |  |
| 15 Misc        | 9/25/20 Friday  |  |  |  |

|         |         | 11:15AM Contractor (Holthouse Const.) installed Lateral lines for Lots<br>150,151, & 152 for Sanitary line 2. |
|---------|---------|---|
| Informa | tional: |   |
| 16      | Misc    | 9/28/20 Monday  |
|         |         | Contractor installed approximately 180' of 8" SDR-26, MH 2-3, & Lot 111 on                                    |
|         |         | Sanitary Line 2.  |

**Comments:**