

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201168
Address: 2724 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, September 28, 2020

Corrective Action Required:

1	Misc	-RECEPTION DESK MEETING ADA REQUIREMENT NOT INSTALLED -PANIC OR FIRE EXIT HARDWARE REQUIRED PER IBC 1010.1.10. DOES NOT MEET EXCEPTION 1->1010.1.9.4(2). OCCUPANT LOAD EXCEED 300
---	------	--

Comments: