

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500  
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Coliform Test 1</b>	Ronald Paynter	Partial	Monday, September 28, 2020

Informational:

1	Misc	Pulled sample from dead end hydrant on line 9. Took sample to Keystone Laboratories for testing. RP 4-30-20
---	------	---

Informational:

2	Misc	First retest of dead end section of line 9 passed it's Bac T test. RP 5-4-20
---	------	--

Informational:

3	Misc	Chlorinated lines 1, 10 and 11. RP 9-28-20
---	------	--

**Comments:**