

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201012  
Address: 1866 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, September 29, 2020

Corrective Action Required:

1	Misc	-Isolate grounded conductors from grounding conductors at sub panel -Install a #4 Cu or #2 Al jumper from lower grounding bus bar to upper grounded bus bar where the service grounded conductor is connected to -Bond the metal connector between meter and disconnect enclosure per 250.92 -Install a missing bonding leg. Don't violate equipment UL listing
---	------	--

**Comments:**