

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20201494
Address: 4720 NE SARATOGA CT, LEES SUMMIT, MO 64064
Inspected On: Tuesday, September 29, 2020
Inspected By: Khanh Nguyen
Expiration Date: 10/29/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Tuesday, September 29, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Sidewalk not approved on record
-Sod, downspout and sump pump extensions
-Make sure that the sewer tracer wire and port are installed and available at grade level
-Install CO/smoke alarm outside bedroom in mud area
-Install dedicated single plug receptacle for AV in mechanical space
-Remove paper facing from insulation |
|---|------|--|