

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200878
Address: 1717 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Tuesday, September 29, 2020

Corrective Action Required:

1	Misc	-Deficient erosion control, shall be in compliance within two business days or stop work order will be issued. -Immediate street, storm box inlet and curb/gutter cleanup required -Remove overgrown weeds and vegetation -Remove trash and debris from site
---	------	---

Comments: