CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500

NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

DE - Water Line - Coliform Test Ronald Paynter Partial Tuesday, September

1 29, 2020

Informational:

1 Misc Pulled sample from dead end hydrant on line 9. Took sample to Keystone

Laboratories for testing. RP 4-30-20

Informational:

2 Misc First retest of dead end section of line 9 passed it's Bac T test. RP 5-4-20

Informational:

3 Misc Chlorinated lines 1, 10 and 11. RP 9-28-20

Informational:

4 Misc Joe Starlin help me dechlorinate water lines 1, 10 and 11. We can pull water

samples any time after 8AM tomorrow. RP 9-29-30

Comments: