

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200309  
Address: 156 NW CARSON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	John Morris	Failed	Wednesday, September 30, 2020

Corrective Action Required:

1	Misc	-Remove trash and construction debris from garage -Final grade per approved plot and sod -Downspouts to discharge minimum 36" from the foundation -Remove paint covers from all smoke and carbon monoxide alarms
---	------	---

**Comments:**