

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200261  
Address: 340 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Wednesday, September 30, 2020

Corrective Action Required:

1	Misc	- METAL STUDS WITH WOOD BUCKS PER PLAN ROOM NEXT TO RECEPTION AREA - - PROVIDE GROMMETS AT PEX LINES IN METAL STUDS AT RESTROOM VANITY -
---	------	---

**Comments:**