



September 24, 2020

Cardinal Crest

Re: 3202 Pergola Park Drive
Pergola Park, Lot 81
Permit # PRES20201772

Apex Engineers, Inc. observed the preparations of the garage slab and patio pier for the proposed house located at the above referenced address.

The garage slab will be structural with a gravel base course. The forms and reinforcing steel were found to be clean, well aligned, properly supported and in compliance with the design.

Note:

- The inspection was performed at 3:30 pm
- At the time of the inspection the temperature was 81°
- Additionally, 1 patio pier was drilled 24" in diameter by 36" deep was also approved.

Our firm recommends approval of the garage slab and patio pier for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,
Apex Engineers, Inc.

Kevin Miller
Engineering Technician

Clayton J. Hess,
Principal

