

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20191872  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>ADA Inspection</b>		Failed	Wednesday, September 30, 2020

Corrective Action Required:  
2 Misc

John DiMauro 9/30/2020 2:23 PM

The Type B - ADA ramp at the southeast of SW Grindstone CIR & SW Georgetown DR is not constructed properly. There is not a sufficient turn around space beyond the detectable warning surface. Corrections to the ramp need to be made before acceptance from the City of Lee's Summit.

A photo of the ramp is uploaded.

**Comments:**