

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20200304  
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Proof Roll</b>	Joe Starlin	Passed	Wednesday, September 30, 2020

Informational:

1	Misc	6-15-20 We proof rolled at 11am. It has passed with at 20 ton load.
		9-24-20 11:35am The truck was to light. He had no proof of load weight.
		9-29-20 1:19am 1:43pm The driveway on the SE side of the site failed.
		9-30-20 2:19pm The driveway has passed the proof roll at this time.

**Comments:**