

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
ADA Inspection	John DiMauro	Passed	Thursday, October 01, 2020

Informational:
2 Misc John DiMauro 10/1/2020 9:36 AM

UPDATE

The Type B - ADA ramp at the southeast corner of SW Grindstone CIR & SW Georgetown DR is IN compliance. The detectable warning surface is allowed to be included in the required 4' ft x 4' ft turning space. No corrective action required.

Comments: