CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20200954

Address: 2918 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

Inspected On: Thursday, October 01, 2020

Inspected By: Patrick Schonfeldt

Expiration Date: 10/29/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Patrick Schonfeldt Temporary C of O Thursday, October

Codes Residential 01, 2020

Corrective Action Required:

1 Misc -Complete final grade and sod

-Splash blocks at all downspout and sump pump discharge

locations, minimum 36" distance from foundation