



ENGINEERING, INC.

Consulting Structural and Civil Engineers

5907 Raytown Trafficway
Raytown, Missouri 64133
816-356-1445 Fax: 816-356-1477

October 1, 2020

Codes Administration
220 SE Green Street
Lee's Summit, MO 64063

**Re: Gloss Nails – 470 NW Chipman Road
Permit No. PRCOM20202233**

Gentlemen,

We are in receipt of plan review comments dated September 25 for the above referenced project and have the following responses.

Fire Plan Review

1. A fire alarm plan, if needed, will be provided by others.
2. A fire sprinkler plan, if needed, will be provided by others.
3. Noted.
4. Noted.

Building Plan Review

2. A water closet has been added in the left rest room. The floor plan was modified to accommodate the extra fixture resulting in minor changes on Sheets 1, E1, E2, M1, and P1.
Partitions have been shown between all fixtures.
No locks are planned for the doors to the rest rooms.

If there are any questions or additional comments, please let me know.

Yours truly,

Albert Hermans, P.E.

