

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Ronald Paynter	Passed	Friday, October 02, 2020

Informational:

1	Misc	Pulled sample from dead end hydrant on line 9. Took sample to Keystone Laboratories for testing. RP 4-30-20
---	------	---

Informational:

2	Misc	First retest of dead end section of line 9 passed it's Bac T test. RP 5-4-20
---	------	--

Informational:

3	Misc	Chlorinated lines 1, 10 and 11. RP 9-28-20
---	------	--

Informational:

4	Misc	Joe Starlin help me dechlorinate water lines 1, 10 and 11. We can pull water samples any time after 8AM tomorrow. RP 9-29-30
---	------	--

Informational:

5	Misc	Meet with Daniel from Redford. We pulled samples from water line 1, 10 and 11. Delivered the samples to Keystone Laboratories for testing. RP 9-30-20
---	------	---

Informational:

6	Misc	Samples from Ashurst, Kaylea and Joshua all passed the first Bac T testing by Keystone Laboratories. RP 10-2-20
---	------	---

Comments: