

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200096
Address: 2313 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, October 02, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Breaker Lockouts on all hardwired appliances- Label all breaker locations at service panel- All downspout and sump pump discharge locations minimum 36" from foundation- Exterior light fixtures less than 8' from grade must be sealed type and not "readily accessible"
---	------	--

Comments: