CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200811

Address: 3521 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 640823521 SW MARKET ST, LEES SUMMIT, MO

64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Electrical Robb Popp Partial Friday, October 02,

Inspection - Commercial 2020

Corrective Action Required:

1 Miscellaneous AREAS APPROVED:

Correction

-CONDUIT FOR SECONDARY POWER FROM TRANSFORMER ON NORTH

CORNER OF LOT TO SOUTHEAST CORNER OF BUILDING

-CONDUIT FROM SOUTHEAST CORNER OF BUILDING TO SOUTHWEST CORNER OF BUILDING FOR MONUMENT SIGN, VAULT, AND FIRE BOX AND EAST FOR

FUTURE USE AND SITE LIGHTING LOOP

-CONDUIT AT SOUTHEAST CORNER OF LOT FOR LIGHT POLE AND FUTURE USE

Comments: