PLANS REVIEW CONDITIONS

Permit No:	PRCOM20201750	Date:	October 02, 2020				
Project Title:	Z HAIR ACADEMY	Applicant:	:				
Location:							
232 NW OLDHAM PKWY, LEES SUMMIT, MO 64081 Type of Work: Occupancy Group: B		ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116					
				Description:	TENANT FINISH FOR HAIR STYLING		042) 000 0647
				SCHOOL		Primary: (913) 888-0647
**invite planner to final to verify rooftop screening							
Construction Typ	e: Type IIB (Unprotected)						
Map Page:							

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review	Reviewed By: Michael Weissenbach	Released for Construction

1. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed. (Action Required)

Riser shall have a current annual inspection tag.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.