

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20200874
Address: 1805 SW RIVER RUN DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed - Stop Work	Tuesday, October 06, 2020

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	-Deficient erosion control, shall be in compliance within two business day or stop work order will be issued. -Immediate street, storm box inlet and curb/gutter cleanup required -Remove trash and debris from site. -Remove overgrown weeds and vegetation.
---	-------------------------	--

Corrective Action Required

2	Misc	10/6/2020- STOP WORK OTDER ISSUED AND PROPERTY POSTED DUE TO NONCOMPLIANCE WITH 9/29/2020 EROSION CONTROL INSPECTION
---	------	--

Comments: