

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082 155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Tuesday, October 06, 2020

Corrective Action Required:

1	Misc	- REMOVE 2ND LAYER OF ROCK TO ALLOW FOR INSPECTION OF 1ST LAYER ROCK EAST SIDE. SCREW PATTERN PER UL LISTING SHOWN IN PLANS
---	------	--

Comments: