

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Patrick Schonfeldt	Failed	Tuesday, October 06, 2020

Informational:

1	Miscellaneous Correction	-FOOTINGS FOR NEW BUILDING LINE ON EAST SIDE OF BUILDING AND DRIVE-THROUGH BUMP OUT ON SOUTH SIDE OF BUILDING
---	--------------------------	---

Corrective Action Required:

2	Misc	- TRASH ENCLOSURE FOOTING POURED WITHOUT INSPECTION. SUBMIT ENGINEER REPORT CONCERNING FOOTING
---	------	--

Comments: