

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172521
Address: 241 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Morris	Failed	Tuesday, October 06, 2020

Corrective Action Required:

1	Misc	-Provide tamper resistant Schrader valves at all condensing units -complete electrical installation for hallway condensing unit -Complete exterior building façade/siding -Label main electrical disconnect as such -Safety glazing stairwell -address gap between wall and concrete slab G 10-7 -broken outboard glazing panel unit 206 -tighten all loose guard rails and handrails -complete rear door installation north building
---	------	---

Comments: