

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192644
Address: 2924 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Joe Starlin	Partial	Tuesday, October 06, 2020

Informational:

1	Misc	10-6-20 7:51am The forms are set and the aggregate is compacted. The contractor knows to stay ADA compliant. 6-7-20 12:26pm The sidewalk finish is wrong and the contractor used clear cure. The city specs are white cure and broom finish. This is a fail.
---	------	---

Comments: