

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20202331  
Address: 200 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Partial	Wednesday, October 07, 2020

Corrective Action Required:

1	Miscellaneous Correction	- PROVIDE MC CABLE ABOVE SUSPENDED CEILING AREAS IN BASEMENT - - MAIN FLOOR OK TO INSULATE & ROCK- - OK TO ROCK WALLS BASEMENT -
---	--------------------------	--

**Comments:**