

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202331
Address: 200 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Partial	Wednesday, October 07, 2020

Corrective Action Required:

1	Miscellaneous Correction	- PROVIDE MC CABLE ABOVE SUSPENDED CEILING AREAS IN BASEMENT - - MAIN FLOOR OK TO INSULATE & ROCK- - OK TO ROCK WALLS BASEMENT -
---	--------------------------	--

Comments: