



ENGINEERING, INC.

Consulting Structural and Civil Engineers

5907 Raytown Trafficway
Raytown, Missouri 64133
816-356-1445 Fax: 816-356-1477

October 7, 2020

Codes Administration
220 SE Green Street
Lee's Summit, MO 64063

**Re: Gloss Nails – 470 NW Chipman Road
Permit No. PRCOM20202233**

Gentlemen,

We are in receipt of plan review comments dated October 5 for the above referenced project and have the following responses.

Building Plan Review

1. The rest rooms have been enlarged to allow for the required ADA turning circle and the partition doors now swing out at the ADA stalls. Minor relocations of outlets, lights, and fixtures are shown on sheets E1, E2, M1, and P1 as a result of the rest room revisions.

If there are any questions or additional comments, please let me know.

Yours truly,

Albert Hermans, P.E.

