

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192738
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	John DiMauro	Passed	Thursday, October 08, 2020

Informational:

1 Misc

John DiMauro 10/8/2020 9:48 AM

I observed the air test for SS sewer lines A & B. The results are as follows.

Line B:

7:34 min test. Line dropped from 4psi to 3.75psi.
Test Passed.

Line A:

MH A-2 to MH A-1 held at 3.75psi with for 7:34 min with no drop.
Test Passed.

MH A-1 to Existing MH 60-191 test for 7:34 min. Psi drop from 3.75 to 3.0psi.
Test Passed.

Comments: