

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200840
Address: 2914 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, October 08, 2020

Corrective Action Required:

1	Misc	-Complete final grade and sod -Place splash blocks at all downspout and sump pump discharge location, minimum 36" from foundation -Label all dedicated outlets in garage and unfinished basement as not GFCI protected -Combustion air vent(s) for furnace, hot water heater
---	------	---

Comments: