

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192738
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	John DiMauro	Passed	Thursday, October 08, 2020

Informational:
1 Misc John DiMauro 10/8/2020 11:24 AM

I observed the mandrel test for both SS lines A & B. The mandrel pulled through both lines with little deflection. The mandrel got hung up at the the inverts for each of the new manholes but was able to be pulled through with additional effort. The crew plans to grind a little of the excess concrete to allow for a smoother transition from the line to the manholes.

Test Passed.

Comments: