# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20200754

Address: 2513 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes John Morris Failed Thursday, October 08,

Residential 2020

## Corrective Action Required:

1 Misc -All outstanding fees must be paid in full

-Final grade Per approved plot plan and sod

-Remove excavation spoils

-Provide gutters and downspouts, downspouts to discharge minimum 36"

from foundation

-Provide in use receptacle cover at exterior HVAC equipment

-Seal top and sides of AC disconnect and exterior lighting exposed to the

elements

-Provide attic access lid

-seal all penetrations in garage rock

-anti-tip at stove

-Label dedicated circuit in basement as non-GFCI protected

-Provide caps for future bathroom group plumbing stubs in basement

-Remove trash and construction debris

-Provide water heater breaker lockout device

-kitchen circuits require AFCI protection

-dishwasher circuit requires GFCI protection

-complete fireplace trim

### **Comments:**