

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192738
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	John DiMauro	Passed	Thursday, October 08, 2020

Informational:

1 Misc

John DiMauro 10/8/2020 1:26 PM

I observed the vacuum tests for the new manholes on SS lines A & B.

MH A-1:

10.5' ft deep. There was a drop from 10" to 9.25" during the 2.5 min test.
Test Passed.

MH A-2:

10.0' ft deep. MH held a vacuum of 10" for 2 min with no drop.
Test Passed.

MH B-1:

10' ft deep. MH held a vacuum of 10" for 2 min with no drop.
Test Passed.

Comments: