CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20182609Address:833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Thursday, October 08, 2020

Corrective Action Required:

1	Miscellaneous			
	Correction	-Signage throughout		
- - - - 4		-Secure windows in stairwells		
		-Seal line set in mechanical closet north		
		-Mechanical closet south-no access		
		-Fire extinguishers/ cabinets in hallway		
		-Cover plates in hallway		
		-Set escutcheon in hall by 406		
		411 seal joint in rock mechanical closet at line set, spark ring microwave,		
		escutcheon in kitchen		
		410 Cover plate in bedroom, seal joint in mechanical closet		
	409 patch hole in mechanical			
		408 place range on anti tip,hammer arrester at sink, spark ring at microwave		
406 a	407 seal gaps and penetration in mechanical closet			
	406 adjust door, seal gap between wall and ceiling in mechanical			
	405 seal gaps in mechanical			
		404 adjust door, seal joint in mechanical closet		
		403 several workers cleaning, inaccessible		
		402 seal penetrations mechanical		
		401 still working		
		400 missing escutcheon in dining, seal line set in mechanical		

Comments: