

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192644
Address: 2924 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|----------------|----------|--------------------------|
| Sidewalk Inspection | Ronald Paynter | Partial | Monday, October 12, 2020 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | 10-6-20 7:51am The forms are set and the aggregate is compacted. The contractor knows to stay ADA compliant. |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 2 | Misc | Forms were placed and aggregate was present and compacted. Needs to adjust forms, close to out of compliance. No picture framing sidewalks any more, brush finish only. Must use white cure. RP 10-12-20 |
|---|------|--|

Comments: