

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193536
Address: 1410 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, October 12, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Complete final grade and sod-Install guardrail at front porch, more than 30" from grade-Place splash blocks at all downspout and sump pump discharge locations, minimum 36" discharge from foundation-Seal all penetrations in siding, seal along top of meter can and AC disconnect-Cleanup construction debris on lot-Anti tip device required in range-Security screws at back door-GFCI protection required at dishwasher-Label all dedicated outlets in garage and unfinished basement as not GFCI protected-Size attic access cover in garage to fit and seal
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: