

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193184
Address: 1409 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, October 12, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Post permanent address-Seal all penetrations in siding, seal along top of meter can and AC disconnect-Splash blocks at all downspout and sump pump discharge locations, minimum 36" discharge from foundation-Complete ceiling light fixture front entry hall-Remove paint covers from all smokes-Garage door must be self closing-GFCI protection required at washing machine receptacle-Complete light fixture at vanity 2nd floor bath-Access required to jacuzzi tub motor master bath-Cut floor joist above furnace for HVAC duct, header off floor joist-Gas service required for occupancy
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: