

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193513
Address: 1508 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, October 12, 2020

Corrective Action Required:

1	Misc	-Resolve outstanding inspection fees before final c of o -Complete final grade and sod -Splash blocks at all downspout and sump pump discharge locations, minimum 36" from foundation -Seal all penetrations in siding, seal along top of meter can and AC disconnect -Complete siding lid at covered patio -Security screws at backdoor -Repair drywall at hood, exposed NM -Label all dedicated outlets in garage and unfinished basement as not GFCI protected -Tempered glass required in window at bottom stair landing, south side -Non combustibile attic access cover required 2nd floor
---	------	---

Comments: