CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201466

Address: 4060 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection		John Jackson	Partial	Friday, September 18, 2020
Informational:				
1	Misc	9/4/20 Friday 1:00PM Construction on 8" sanitary Line "B" from MH 2 to and through the installation of MH 3. Contractor continues to install line and will begin to install laterals for Lots 15 and 14. Contractor plans on working Saturday.		
Informational:				
2	Misc	9/8/20 Tuesday 11:30AM Beemer Const. Has installed all wyes on new Line "B" and is projected to finish installing new MH B-4 today.		
Informational:				
3	Misc	9/9/20 8:25AM (Beemer Const.) Contractor completed the installation of sanitary Line "B". Contractor began install Line "A" at the existing manholes.		
Informational:				
4	Misc	9/15/20 3:10PM 9/14/20 Contractor installed and lateral line for Lot 24.	ed approximately 60' of 8" S	DR-26 pipe on Line A

Informational:

5 Misc 9/16/20 Wednesday Contractor installed MH A-1 and approximately 90' of 8"

SDR-26 PVC on sanitary Line A. Lot 19 (1-3) lateral line was installed, and Lot

9/15/20 Contractor sawed existing invert to make a correct opening for that was cored to compile with design construction standard. Some excavation

10 (1-3) lateral line.

work was performed.

Informational:

6 Misc 9/17/20 3:07PM Thursday Contractor installed approximately 50' of 8" SDR-26

PVC on sanitary Line A. Lot 19 (2-3) & (3-3) and Lot 10 (2-3) & (3-3) lateral

lines.

Informational:

7 Misc 9/18/20 2:53 Friday Contractor installed approximately 60" of 8" SDR-26 PVC

on sanitary Line A.

Lot 11 (1-3) & Lot 18 (1-3) Lateral lines were installed.

Comments: