

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201526
Address: 1528 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, October 13, 2020

Corrective Action Required:

1	Miscellaneous Correction	-Truss hangers per plans- missing at truss J1 in dining room -Missing/ bent nails in truss hangers in garage -Seal fire block in deadspace at laundry
---	--------------------------	---

Comments: