

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201144
Address: 2939 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, October 13, 2020

Corrective Action Required:

1	Misc	-Complete final grade and sod -Guardrail required at front porch, more than 30" from grade -Splash blocks at all downspout and sump pump discharge locations, minimum 36" distance from foundation -Install handle/lock on sliding patio door, two locking devices required on sliding doors -Hood exhaust required at range -repair drywall at bath counter receptacle 2nd floor
---	------	--

Comments: