

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20191873  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	John DiMauro	Passed	Tuesday, October 13, 2020

Informational:

1 Misc

John DiMauro 10/13/2020 12:33 PM

I observed the hydrostatic pressure test for the water line. The gauge was pressurized to 155 psi and it held for two hours with no drop.

Test Passed.

**Comments:**