CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection - Patrick Schonfeldt Failed Tuesday, October 13,

Commercial 2020

Corrective Action Required:

1 - TYPE OF CLAMP USED ON STEEL BEAM BOND, RATED FOR USE

-SAND PAINT OFF BEAM AT BONDING CLAMP -BRING WATER BOND UP FROM BELOW GRADE -COMPLETE METER/DISCONNECT INSTALL

-SUBMIT CURRENT LINE DRAWING, NOT CURRENTLY AS SHOWN IN PLANS

Comments: