

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200262
Address: 149 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	John Morris	Failed	Wednesday, October 14, 2020

Corrective Action Required:

1	Miscellaneous Correction	-grade shall fall not less than 6" within the first 10' from the foundation -6" clearance from grade below to wood siding or sheathing -remove excavation spoils from site
---	-----------------------------	--

Comments: