

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202666  
Address: 4708 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, October 14, 2020

Corrective Action Required:

1	Misc	-REPAIR DRAIN TILES -RUN TRACER WIRE UP FOUNDATION WALL ABOVE GRADE -PROVIDE GRAVEL SUPPORT FOR SEWER PIPING
---	------	--------------------------------------------------------------------------------------------------------------------

**Comments:**