

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202013
Address: 3121 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, October 14, 2020

Corrective Action Required:

1	Misc	- UNCOVER INTERIOR DRAIN TILE FROM GRAVEL COVER FOR INSPECTION
---	------	----------------------------------------------------------------

Comments: