

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200763
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Wednesday, October 14, 2020

Informational:	
1 Misc	- ROOF SHEATHING NAILING PATTERN ONLY -
Corrective Action Required:	
2 Misc	- TIGHTEN ANCOR BOLTS AT HOLD DOWNS - - PROVIDE ANCHOR BOLTS WITHIN 12" OF PLATE BREAK - - PROVIDE NAIL GUARDS GAS LINES -

Comments: